


序号	报告编号	发布日期	结论	影像资料
197	GX-B1360/21-2-24036~24038	2024. 9. 29	本次共检验低压断路器3台，3台所检项目合格。	
198	GX-B1310/21-2-24303	2024. 9. 26	符合标准要求。	
199	GX-B1427/21-2-24303	2024. 9. 26	符合标准要求。	

200	GX-B1310/21-2-24304	2024. 9. 26	符合标准要求。	
201	GX-B1427/21-2-24304	2024. 9. 26	符合标准要求。	
202	GX-B1310/21-2-24313	2024. 9. 26	符合标准要求。	

203	GX-B1428/21-2-24313	2024. 9. 26	无缺陷迹痕显示。	
204	GX-B1418/23-2-24021	2024. 9. 30	综合判定合格	
205	GX-B1328/20-2-24090	2024. 9. 30	本次共检绝缘手套8只，8只所检项目合格。	

206	GX-B1328/20-2-24091	2024. 9. 30	本次共检绝缘鞋8只，8只所检项目合格。		
207	GX-B1416/22-2-24027	2024/9/30	综合判定：合格。		
208	GX-B1598/24-2-24185	2024. 9. 30	实测钢丝绳有效截面积损失百分比最大为4.17%，小于5%为正常。		

209	GX-B1598/24-2-24186	2024. 9. 30	实测钢丝绳有效截面积损失百分比最大为4.31%，小于5%为正常。			
-----	---------------------	-------------	----------------------------------	--	---	--